

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-1374:100 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: NCA, 1735 Mattawa Ave., Mississauga, Ontario, Canada L4X 1K5
Contact: Darryl Miller (905) 270-0480

DESIGN: Model VA series fire damper. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name and UL label.

APPROVAL: Listed as a fire damper for use in areas requiring up to 3-hour protection.

NOTE: Leakage rating not evaluated. Refer to Category 3230 for listed leakage dampers.

NOTE: Formerly 3225-1044:101



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 5, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager